

ITS Labtest Bangladesh Ltd.
Intertek House Bangladesh Ltd.
Phoenix Tower (2nd-3rd Floor), 407,
Tejgaon I/A, Dhaka-1208, Bangladesh.
www.intertek.com

Report Number: BA-ENV-2023-08 Date: 09 March, 2023

WORKPLACE ENVIRONMENTAL ASSESSMENT REPORT

Stack Air Emission Assessment (Boilers)

Facility Name : IRIS Fabrics Limited.

Facility Address : Zirani Bazar, Kashimpur, Gazipur

GPS Coordinate : Latitude : 23.999265 | Longitude: 90.251186

Facility Tel : +8801817049518

Facility Contact : Mohammad Ahsan Alim – GM (Admin, HR & compliance)

Facility Email : admin@irisgroupbd.com

Description of Equipment: KANE975-Industrial Flue Gas Analyzer, Model No: UEi K975,

ECOTECH, Model: ESS100

Data Collection Date & Time : 09 March 2023, 10:40 AM-02:55 PM (Running Condition)

Conducted By : Md. Monoarul Islam, & Hasan Tawhid

Description of Boilers:

Machine	Key Information						
	Location	Capacity	Brand Name	Registration Number	Fuel Type		
Boiler-1	Boiler Room	14 Ton	Bosch	Ba. Bo. 4935	Gas		
Boiler-2	Boiler Room	10.8 Ton	MECHMAR	Ba. Bo. 10119	Gas		

Assessment Result:

Machine Type	SPM (mg/Nm³)	NO _x (mg/Nm³)	SO₂ (mg/Nm³)	CO (mg/Nm³)	CO₂ (%)	O ₂ (%)
Boiler- 1	55.2	45.2	0	81.3	3.5	2.8
Boiler- 2	50.1	39.5	0	72.2	3.3	2.7

^{*} SPM is tested from another ISO-17020:2012 accredited inspection body



Report Number : BA-ENV-2023-08 Date : 09 March, 2023 ITS Labtest Bangladesh Ltd.
Intertek House Bangladesh Ltd.
Phoenix Tower (2nd-3rd Floor), 407,
Tejgaon I/A, Dhaka-1208, Bangladesh.
www.intertek.com

Standard Requirement

		Air Quality Parameters						
Standard	Fuel	O ₂	CO	CO ₂	NO _x	SO ₂	SPM	
		%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm³	
ECR- 1997	Gas	NYS	NYS	NYS	150	NYS	100	
Len 1997	Diesel	NYS	NYS	NYS	300	NYS	300	
Air Pollution (Control)	Gas	NYS	NYS	NYS	300	250	NYS	
Rules- 2022	Diesel	NYS	NYS	NYS	400	250	200	
IFC/ WB standard	Gas	3	NYS	NYS	320	NYS	NYS	
IFC/ WD Standard	Diesel	3	NYS	NYS	460	2000	50-150	

^{*}NYS= Not Yet Set; ECR= Environmental Conservation Rules

Abbreviation : SPM (Suspended Particulate Matter), PM10 (Respirable Dust Content), PM2.5 (Fine Particulate Matter), SO₂ (Sulphur-Di-Oxide), NO_x (Oxides of Nitrogen), CO (Carbon Monoxide), CO₂ (Carbon di-oxide), WB (World Bank).

Comment: Assessment result of stack air emission of Boilers shows that the concentrations of air quality parameters has been found within the acceptable limit.

Report prepared by

Md. Monoarul Islam Auditor Supplier Management

M. Alem

Business Assurance ITS Labtest Bangladesh Ltd.

Report authorized by

oriful Isla

Shoriful Islam
Head of Business Assurance
Supplier Management
Business Assurance
ITS Labtest Bangladesh Ltd.