

ITS Labtest Bangladesh Ltd.
Intertek House Bangladesh Ltd.
Phoenix Tower (2<sup>nd</sup>-3<sup>rd</sup> Floor), 407,
Tejgaon I/A, Dhaka-1208, Bangladesh.
www.intertek.com

Report Number: ITS-ENV-2024-06-F Date : 03 April, 2024

# WORKPLACE ENVIRONMENTAL ASSESSMENT REPORT

# **Stack Air Emission Assessment (Boilers)**

Facility Name : IRIS Fabrics Limited.

Facility Address : Zirani Bazar, Kashimpur, Gazipur

GPS Coordinate : Latitude: 23.999265 | Longitude: 90.251186

Facility Tel : +8801817049518

Facility Contact : Mohammad Ahsan Alim – GM (Admin, HR & compliance)

Facility Email : admin@irisgroupbd.com

**Description of Equipment**: KANE975-Industrial Flue Gas Analyzer, Model No: UEi K975,

ECOTECH, Model: ESS100

Data Collection Date & Time : 31 March 2024, 9:15 AM-2:25 PM (Running Condition)

Conducted By : Mohammad Waliullah & Kamrun Nahar

## **Description of Boilers:**

Key Information	Boiler Description						
Machine	Boiler-1	Boiler-2	Boiler-3(EGB)				
Location	Boiler Room	Boiler Room	Boiler room				
Registration Number	Ba.Bo.4935	Ba.Bo. 10119	Ba Bo 12627				
Capacity	10.88 Ton	14 Ton	1.2 ton				
Brand	Mechmar	Bosch	Thermax				
Fuel Type	Gas	Gas	Exhaust Fumes from Generator				

#### **Assessment Result:**

Machine Type	SPM	NO <sub>x</sub>	SO <sub>2</sub>	CO	CO <sub>2</sub>	<b>O</b> <sub>2</sub>
	(mg/Nm <sup>3</sup> )	(mg/Nm³)	(mg/Nm³)	(mg/Nm³)	(%)	(%)
Boiler- 1	82	52	0	72.5	7.8	6.92
Boiler- 2	78	17	0	58.2	7.0	8.16
Boiler-3(EGB)	62	92	0	52.2	7.1	8.05



ITS Labtest Bangladesh Ltd.
Intertek House Bangladesh Ltd.
Phoenix Tower (2<sup>nd</sup>-3<sup>rd</sup> Floor), 407,
Tejgaon I/A, Dhaka-1208, Bangladesh.
www.intertek.com

Report Number: ITS-ENV-2024-06-F Date : 03 April, 2024

## Standard Requirement :

		Air Quality Parameters					
Standard	Fuel	O <sub>2</sub>	СО	CO <sub>2</sub>	NO <sub>x</sub>	SO <sub>2</sub>	SPM
		%	mg/Nm³	mg/Nm³	mg/Nm <sup>3</sup>	mg/Nm³	mg/Nm³
ECR- 1997	Gas	NYS	NYS	NYS	150	NYS	100
	Diesel	NYS	NYS	NYS	300	NYS	300
Air Pollution (Control) Rules- 2022	Gas	NYS	NYS	NYS	300	250	NYS
	Diesel	NYS	NYS	NYS	400	250	200
IFC/ WB standard	Gas	3	NYS	NYS	320	NYS	NYS
	Diesel	3	NYS	NYS	460	2000	50-150

<sup>\*</sup>NYS= Not Yet Set; ECR= Environmental Conservation Rules

**Abbreviation :** SPM (Suspended Particulate Matter), PM10 (Respirable Dust Content), PM2.5 (Fine Particulate Matter), SO<sub>2</sub> (Sulphur-Di-Oxide), NO<sub>x</sub> (Oxides of Nitrogen), CO (Carbon Monoxide), CO<sub>2</sub> (Carbon di-oxide), WB (World Bank).

**Comment:** Assessment result of stack air emission of Boilers shows that the concentrations of air quality parameters has been found within the acceptable limit.

### Report prepared by

Will

Mohammad Waliullah Auditor Supplier Management Business Assurance ITS Labtest Bangladesh Ltd.

## Report authorized by

A. A.

Shoriful Islam
Head of Business Assurance
Supplier Management
Business Assurance
ITS Labtest Bangladesh Ltd.